

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Dimmer switch for fixed installation

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No.39 Hechang 6th Rd.,
HZZK Hi-tech Industrial Development Zone, Huizhou,
Guangdong, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

220-240V~ 50/60Hz IP20
60-500W Incandescent / halogen

Trademark (if any)

legrand

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

281080, 283880, 282080, 617631, 617731, 617831

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60669-1:1998+A1+A2
IEC 60669-2-1:2002+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

210500415SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Date: 24 June, 2021

Hyden Li

