

**IEC****IECEE**

®

™

Ref. Certif. No.

**FR\_716168****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

**Socket-outlet for fixed-electrical installations**

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series SOLIROC  
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 651134 dated 11/06/2014. Update further to the evolution of the standard(s)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

14332368-776578

This CB Test Certificate is issued by the National Certification Body

**LCIE**LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE[www.lcie.fr](http://www.lcie.fr)LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUESS.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSESSignature:   
**Julien GAUTHIER**  
Certification Officer

Date: 21/12/2022

## ANNEX

**Name and address of the factories:****LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

**LEGRAND FRANCE ISERE**

PLACE DU BREUIL  
38680 PONT EN ROYANS  
FRANCE

**BTICINO SPA**

VIALE LUIGI BORRI 231  
21100 VARESE  
ITALY

**ERP ELBROMPLAST**


CALEA VIDRIGHIN STAN N° 13A  
300571 TIMISOARA  
ROMANIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE

[www.lcie.fr](http://www.lcie.fr)

Date: 21/12/2022



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**  
Certification Officer

## ANNEX

### References, ratings and main characteristics:

Socket-outlet for electric vehicle charging, SOLIROC series

References	Characteristics
0 778 56	With cover, sold with accessory 0 904 78
0 778 57	With locked cover sold with 2 unique keys and accessory 0 904 78

Standard Sheet	III (CEE7)
Rated current (A)	16 A
Rated voltage (V)	250 V~
Degree of protection	IP55
Provision for earthing	with earthing contact
Method of connecting the cable	rewirable
Type of terminals	screw-type
Colour	grey
Pins	not solid
Degree of protection against electric shock	increased protection
Existence of shutters	with shutters
Method of application - mounting	flush-type or surface type
Method of installation	design A
Degrees of protection against external mechanical impacts	IK10


### **ACCESSORIES**

References	Designation
0 778 51	cover plate
0 778 90	box for surface-type mounting
0 904 78	peg fixation



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 21/12/2022



Signature: **Julien GAUTHIER**  
 Certification Officer