

IEC**IECEE**

Ref. Certif. No.

FR_706408/M1**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Fixed-socket-outlet

Socket-outlets for fixed installations

Name and address of the applicant

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRtIPARTELEPI UT 14 PF 10
6600 SZENTES - HUNGARY

Name and address of the manufacturer

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRtIPARTELEPI UT 14 PF 10,
6600 SZENTES - HUNGARY

Name and address of the factory

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRtIPARTELEPI UT 14 PF 10,
6600 SZENTES - HUNGARY

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

572111, 572611, 570038, 571038

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_706408 dated 22/07/2019.
re-issue date Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002+A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P22071953

This CB Test Certificate is issued by the National Certification Body

**LCIE**

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.fr

Date: 20/09/2022

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES

S.A.S au capital de 15,745,984 €

RCS Nanterre B 408 363 174

33 avenue du Général Leclerc

F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

ANNEX

REFERENCES, RATING AND MAIN CHARACTERISTICS

Reference	Range*	Description	Color of enclosure	with cover plate	with support frame
572111	ARTEOR	2P+E 13A British Standard unswitched 1 gang	White	575210	576003
572611	ARTEOR	2P+E 13A British Standard unswitched 1 gang	Magnesium	571312	576003
570038	ARTEOR	2P+E 13A British Standard unswitched 1 gang	Champagne	571322	576003
571038	ARTEOR	2P+E 13A British Standard unswitched 1 gang	Alu	571302	576003

* The "range" denotes applicant's categorization.

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	See the table above
socket-outlets	
multiple socket-outlets	
number of socket-outlets	13A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 20/09/2022



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer