

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	Multiple cord extension set
Name and address of the applicant	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the factory	DONGGUAN QUAN SHENG ELECTRIC Co., Ltd 2nd Industry Zone, Jutang, Housha Road Houjie Town, Dongguan, Guangdong 523963 - CHINA
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Max. 3680 W , 230 V~, 50 Hz See Annex
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	6 948 12
Additional information (if necessary may also be reported on page 2)	/ <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013 IEC 60884-2-7:2011 +A1:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	AAWX-18OC0125ACSHP-1, AAWX-18OC0125ACSHP

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 18/04/2019

Signature: Jean-françois BRUEL
Certification Officer

ANNEX


RATING AND MAIN CHARACTERISTICS

standard Sheet:	Standard sheet III of CEE7
rated current (A)	16 A
rated load (W)	3680 W
rated voltage (V)	250 V~
household voltage (V)	230 V~
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	non-rewirable
type of terminals	termination
type of connections	soldered –welded –other(riveted)
socket-outlets	
multiple socket-outlets	16A :4
number of socket-outlets	
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	portable type
plugs:	
class of equipment	I

Component	Model	Manufacturer	Conformity
Plug	SD-006	Dongguan Quan Sheng Electric Co., Ltd.	DEKRA
Cable	H05VV-F 3G1,5mm ²	Dongguan Quan Sheng Electric Co., Ltd.	DEKRA
USB	FT838-3.4A	LEGRAND FRANCE	BV test report LD180926N073
Switch	PS-5	Canal Electronic Co., Ltd.,	VDE



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 18/04/2019

Signature: Jean-françois BRUEL
Certification Officer