



Ref. Certif. No.

FR_719161

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Plug
Rewirable plug

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

NINGBO BANMEN ELECTRIC APPLIANCE CO., LTD.
East Industrial Zone, Guanhaiwei, Cixi City, 315314
Zhejiang Province - CHINA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 592123/M1 dated 15/03/2011.
Update the list of product references
Update further to the evolution of the standard(s)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P22120933

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

Date: 24/05/2024

ANNEX


RATING AND MAIN CHARACTERISTICS

Model	Reference	Entry of cable	Color of enclosure	With label
HE14	0 501 77	longitudinal	BLACK	/
	0 503 15	longitudinal	WHITE	/
	0 501 87	longitudinal	WHITE	with label
HE15	0 501 78	lateral	BLACK	/
	0 503 16	lateral	WHITE	/
	0 501 88	lateral	WHITE	with label

standard Sheet:	standard sheet IV of CEE7
rated current (A)	16A
rated load (W)	-
rated voltage (V)	250V
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	See label above
plugs:	
class of equipment	I



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Date: 24/05/2024

Signature: Julien GAUTHIER
Certification Officer