

IEC**IECEE**

Ref. Certif. No.

FR_713498/M1**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

LEGRAND FRANCE
159 RUE JEAN JOANNON - ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
159 RUE JEAN JOANNON - ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

Name and address of the factory

See Annex

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

RCCB 2P
Series : TX³, XC³, XC10, RX³, DX³
See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_713498 dated 2022/04/04. Addition of product references

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010 +A1:2012 +A2:2013
IEC 61008-2-1:1990

As shown in the Test Report Ref. No. which forms part of this Certificate

N° 152863-715114A, 152863-715114 A1 to 152863-715114 A42,
N° 13052232-774277/A, 13052232-774277/A1 to
13052232-774277 /A9
N° 18445368-787688, 18445368-787688/1, 18445368-787688/2

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B-498 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature:
Julien GAUTHIER
Certification Officer

ANNEX**Name and address of the factories:****LEGRAND ELEKTRIK SANAYI A.S**

GOSB GEBZE ORGANIZE SANAYI BOLGESI - IHSAN DEDE CADDESİ N°112
41480 GEBZE KOCAELI
TURKEY

LEGRAND FRANCE

159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

LEGRAND FRANCE

290 AVENUE DE COLMAR
67100 STRASBOURG
FRANCE

NOVATEUR ELECTRICAL AND DIGITAL SYSTEMS PRIVATE LIMITED

D-4 MIDC INDUSTRIAL AREA,
AJANTHA ROAD,
JALGAON – 425003
MAHARASHTRA
INDIA


M/S NOVATEUR ELECTRICAL AND DIGITAL SYSTEMS PRIVATE LIMITED

UNIT-II, BLOCK-A, B & D / UNIT-III, BLOCK C, Plot No-2, Sector-2, IIE, SIDCUL
HARIDWAR – 249402
UTTRAKHAND
INDIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 11/07/2023

ANNEX

References, ratings and main characteristics:

Reference TX ³ « Germanique » series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
4115 02	16 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1210	25 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3450	16 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 09	25 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 10	40 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 11	63 A	230 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 12	80 A	230 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
4115 13	100 A	230 V~	30 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3451	16 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 19	25 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 20	40 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 21	63 A	230 V~	100 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 22	80 A	230 V~	100 mA	AC	800 A	1 000 A	10 000 A	10 000 A
4115 23	100 A	230 V~	100 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3452	16 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 29	25 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 30	40 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 31	63 A	230 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 32	80 A	230 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
4115 33	100 A	230 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3453	16 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1211	25 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1212	40 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1213	63 A	230 V~	500 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG1214	80 A	230 V~	500 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1215	100 A	230 V~	500 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3454	16 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1216	25 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1217	40 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
4115 39	63 A	230 V~	100 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG1218	80 A	230 V~	100 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
LG1219	100 A	230 V~	100 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien GAUTHIER
 Certification Officer

ANNEX

Reference TX ³ « Germanique » series	I _n	U _n	IΔ _n	Type	I _m	IΔ _m	I _{nc}	IΔ _c
LG3455	16 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1220	25 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1221	40 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
4115 47	63 A	230 V~	300 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG1222	80 A	230 V~	300 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
LG1223	100 A	230 V~	300 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A

LG3456	16 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3457	25 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3458	40 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3459	63 A	230 V~	500 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG3460	80 A	230 V~	500 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
LG3461	100 A	230 V~	500 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A

4115 52 4119 10	16 A	230 V~	10 mA	A	500 A	1000 A	10000A	10000A
LG3480	25 A	230 V~	10 mA	A	500 A	1000 A	10000A	10000A


LG3481	16 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 59 4119 11	25 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 60 4119 12	40 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 61 4119 13	63 A	230 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
4115 62 4119 14	80 A	230 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1225	100 A	230 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3482	16 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 64	25 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 65	40 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 66	63 A	230 V~	100 mA	A	630 A	1 000 A	10 000 A	10 000 A
4115 67	80 A	230 V~	100 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1226	100 A	230 V~	100 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



Signature: *Julien GAUTHIER*
 Certification Officer

ANNEX

Reference TX ³ « Germanique » series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG3483	16 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 74	25 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 75 4119 22	40 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 76 4119 23	63 A	230 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
4115 77 4119 24	80 A	230 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1227	100 A	230 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3484	16 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 79	25 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 80	40 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1228	63 A	230 V~	500 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG1229	80 A	230 V~	500 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1230	100 A	230 V~	500 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3485	16 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1231	25 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1232	40 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1233	63 A	230 V~	100 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1234	80 A	230 V~	100 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1235	100 A	230 V~	100 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A


LG3486	16 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1236	25 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1237 4119 27	40 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
4115 87 4119 28	63 A	230 V~	300 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1238	80 A	230 V~	300 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1239	100 A	230 V~	300 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A

LG3487	16 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1240	25 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1241	40 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1242	63 A	230 V~	500 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1243	80 A	230 V~	500 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1244	100 A	230 V~	500 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



Signature: *Julien GAUTHIER*
 Certification Officer

ANNEX

Reference TX ³ « Germanique » series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
--	----	----	-----	------	----	-----	-----	-----

References for Brazilian and Mexican market

LG7204	16 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7205	25 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7206	40 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7207	63 A	127 / 220 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG7208	80 A	127 / 220 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7209	100 A	127 / 220 V~	30 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG7210	16 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7211	25 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7212	40 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7213	63 A	127 / 220 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG7214	80 A	127 / 220 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7215	100 A	127 / 220 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A


LG7216	16 A	127 / 220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7217	25 A	127 / 220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7218	40 A	127 / 220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7219	63 A	127 / 220 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG7220	80 A	127 / 220 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7221	100 A	127 / 220 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG7222	16 A	127 / 220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7223	25 A	127 / 220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7224	40 A	127 / 220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7225	63 A	127 / 220 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG7226	80 A	127 / 220 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7227	100 A	127 / 220 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 11/07/2023

ANNEX

Reference TX ³ « Germanique » other ranges series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG7562	16 A	230V~	10mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7563	25 A	230V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A

LG7374 LG7602	16 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7375 LG7603	25 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7376 LG7604	40 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7377 LG7605	63 A	230V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG7378 LG7606	80 A	230V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7379 LG7607	100 A	230V~	30 mA	AC	100 A	1 000 A	10 000 A	10 000 A
LG7564	16 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7565	25 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7566	40 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7567	63 A	230V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG7568	80 A	230V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7569	100 A	230V~	300 mA	AC	1000 A	1 000 A	10 000 A	10 000 A

LG7570	16 A	230V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7571	25 A	230V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A

LG7380 LG7608	16 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7381 LG7609	25 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7382 LG7610	40 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7383 LG7611	63 A	230V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG7384 LG7612	80 A	230V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7385 LG7613	100 A	230V~	30 mA	A	1000A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer

ANNEX

Reference TX ³ « Germanique » other ranges series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG7572	16 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7573	25 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7574	40 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7575	63 A	230V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG7576	80 A	230V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7577	100 A	230V~	300 mA	A	1000A	1 000 A	10 000 A	10 000 A

LG7590	16 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7591	25 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7592	40 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG7593	63 A	127/220 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG7594	80 A	127/220 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7595	100 A	127/220 V~	30 mA	AC	1000 A	1 000 A	10 000 A	10 000 A
LG7596	16 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7597	25 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7598	40 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG7599	63 A	127/220 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG7600	80 A	127/220 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7601	100 A	127/220 V~	30 mA	A	1000A	1 000 A	10 000 A	10 000 A

Reference TX ³ "LATIN" series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG1255 LG7386	16 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1256 LG7387	25 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A

LG3400 LG7414	16 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 00 4030 32 LG7415	25 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 01 4030 33 LG7416	40 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 02 LG7417	63 A	230 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG1253 LG7418	80 A	230 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1254 LG7419	100 A	230 V~	30 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 561 111
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien GAUTHIER*
Certification Officer


ANNEX

Reference TX ³ "LATIN" series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG3401 LG7388	16 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3406 LG7389	25 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3407 LG7390	40 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3408 LG7391	63 A	230 V~	100 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG3403 LG7392	80 A	230 V~	100 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG3404 LG7393	100 A	230 V~	100 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3405 LG7394	16 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 38 LG7395	25 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 39 LG7396	40 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4030 40 LG7397	63 A	230 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG3409 LG7398	80 A	230 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG3410 LG7399	100 A	230 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3411	16 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3412	25 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3413	40 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3414	63 A	230 V~	500 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG3415	80 A	230 V~	500 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG3416	100 A	230 V~	500 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A
LG3417 LG7400	16 A	230 V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3418 LG7401	25 A	230 V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG 3419 LG7420	16 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4030 35 LG7421	25 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4030 36 LG7422	40 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1250 LG7423	63 A	230 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG1251 LG7424	80 A	230 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1252 LG7425	100 A	230 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 11/07/2023

ANNEX

Reference TX ³ "LATIN" series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG3420 LG7402	16 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3421 LG7403	25 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3422 LG7404	40 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3423 LG7405	63 A	230 V~	100 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG3424 LG7406	80 A	230 V~	100 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG3425 LG7407	100 A	230 V~	100 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3426 LG7408	16 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3427 LG7409	25 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3428 LG7410	40 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3429 LG7411	63 A	230 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG3430 LG7412	80 A	230 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG3431 LG7413	100 A	230 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3432	16 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3433	25 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3434	40 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG3435	63 A	230 V~	500 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG3436	80 A	230 V~	500 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG3437	100 A	230 V~	500 mA	A	1 000 A	1 000 A	10 000 A	10 000 A


Reference XC10 series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG7772	16 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 82	25 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 83	40 A	230V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 84	63 A	230V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4 331 85	80 A	230V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7773	100 A	230V~	30 mA	AC	1000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 11/07/2023



Signature: *Julien GAUTHIER*
Certification Officer

ANNEX

Reference XC10 series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG7774	16 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 86	25 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 87	40 A	230V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4 331 88	63 A	230V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4 331 89	80 A	230V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG7775	100 A	230V~	300 mA	AC	1000 A	1 000 A	10 000 A	10 000 A

LG7768	16 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 24	25 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 25	40 A	230V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 26	63 A	230V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
4 332 27	80 A	230V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7769	100 A	230V~	30 mA	A	1000A	1 000 A	10 000 A	10 000 A

LG7770	16 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 28	25 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 29	40 A	230V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4 332 30	63 A	230V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
4 332 31	80 A	230V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG7771	100 A	230V~	300 mA	A	1000A	1 000 A	10 000 A	10 000 A

Reference XC ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
4031 82	25 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4031 83	40 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4031 84	63 A	230 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4031 85	80 A	230 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A

4031 86	25 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4031 87	40 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4031 88	63 A	230 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4031 89	80 A	230 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A

4032 24	25 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4032 25	40 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4032 26	63 A	230 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
4032 27	80 A	230 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A

4032 28	25 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4032 29	40 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4032 30	63 A	230 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
4032 31	80 A	230 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 263 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: *Julien GAUTHIER*
 Julien GAUTHIER
 Certification Officer

Date: 11/07/2023

ANNEX

Reference RX ^s series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG2300 LG7366	16 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 24 4020 56	25 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 25 4020 57	40 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 26 LG7367	63 A	230 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4020 27 LG7368	80 A	230 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1202 LG7369	100 A	230 V~	30 mA	AC	1000 A	1 000 A	10 000 A	10 000 A

LG2301	16 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 28	25 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 29	40 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 30	63 A	230 V~	100 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG1203	80 A	230 V~	100 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1204	100 A	230 V~	100 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG2302	16 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 32	25 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 33	40 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 34	63 A	230 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG1205	80 A	230 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1206	100 A	230 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG2303	16 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2304	25 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2305	40 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2306	63 A	230 V~	500 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG2307	80 A	230 V~	500 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG2308	100 A	230 V~	500 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG2309 LG7370	16 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4020 36 4020 59	25 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4020 37 4025 35 4020 60	40 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4020 38 4025 36 LG7371	63 A	230 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG2310 LG7372	80 A	230 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG2311 LG7373	100 A	230 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
 Julien GAUTHIER
 Certification Officer

Date: 11/07/2023

ANNEX

Reference RX ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG2312	16 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2313	25 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2314	40 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2315	63 A	230 V~	100 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG2316	80 A	230 V~	100 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG2317	100 A	230 V~	100 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG2318	16 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2319	25 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2320 4025 37	40 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2321 4025 38	63 A	230 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG2322	80 A	230 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG2323	100 A	230 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG2324	16 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2325	25 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2326	40 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG2327	63 A	230 V~	500 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG2328	80 A	230 V~	500 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG2329	100 A	230 V~	500 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

References for Brazilian and Mexican market

LG2340	16 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 86	25 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 87	40 A	127 / 220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4020 88	63 A	127 / 220 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG2341	80 A	127 / 220 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG2342	100 A	127 / 220 V~	30 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG2343	16 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2344	25 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2345	40 A	127 / 220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG2346	63 A	127 / 220 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG2347	80 A	127 / 220 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG2348	100 A	127 / 220 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 384 647 111
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: *Julien GAUTHIER*
 Certification Officer

ANNEX

Reference DX ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
4115 00	16 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 01	25 A	230 V~	10 mA	AC	500 A	1 000 A	10 000 A	10 000 A

LG3300	16 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 04	25 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 05	40 A	230 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 06	63 A	230 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 07	80 A	230 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A
4115 08	100 A	230 V~	30 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG3301	16 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 14	25 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 15	40 A	230 V~	100 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 16	63 A	230 V~	100 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 17	80 A	230 V~	100 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1060	100 A	230 V~	100 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG3302	16 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 24	25 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 25	40 A	230 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
4115 26	63 A	230 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
4115 27	80 A	230 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
4115 28	100 A	230 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG3303	16 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1061	25 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1062	40 A	230 V~	500 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG1063	63 A	230 V~	500 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG1064	80 A	230 V~	500 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG1065	100 A	230 V~	500 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG3304	16 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1080	25 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1081	40 A	230 V~	100 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1082	63 A	230 V~	100 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG1083	80 A	230 V~	100 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
4115 37	100 A	230 V~	100 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: **Julien GAUTHIER**
 Certification Officer

ANNEX

Reference DX ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG3305	16 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1084	25 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG1085	40 A	230 V~	300 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
4115 43	63 A	230 V~	300 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG1086	80 A	230 V~	300 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
LG1087	100 A	230 V~	300 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A

LG3306	16 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3307	25 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3308	40 A	230 V~	500 mA	AC-S	500 A	1 000 A	10 000 A	10 000 A
LG3309	63 A	230 V~	500 mA	AC-S	630 A	1 000 A	10 000 A	10 000 A
LG3310	80 A	230 V~	500 mA	AC-S	800 A	1 000 A	10 000 A	10 000 A
LG3311	100 A	230 V~	500 mA	AC-S	1 000 A	1 000 A	10 000 A	10 000 A

4115 50	16 A	230 V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1040	25 A	230 V~	10 mA	A	500 A	1 000 A	10 000 A	10 000 A

LG3330	16 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 54	25 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 55	40 A	230 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 56	63 A	230 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
4115 57	80 A	230 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1041	100 A	230 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A


LG3331	16 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1042	25 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1043	40 A	230 V~	100 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1044	63 A	230 V~	100 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG1045	80 A	230 V~	100 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1046	100 A	230 V~	100 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3332	16 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 69	25 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 70	40 A	230 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4115 71	63 A	230 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
4115 72	80 A	230 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1047	100 A	230 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



Signature: *Julien Gauthier*
 Julien GAUTHIER
 Certification Officer

ANNEX

Reference DX ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
LG3333	16 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1048	25 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1049	40 A	230 V~	500 mA	A	500 A	1 000 A	10 000 A	10 000 A
LG1050	63 A	230 V~	500 mA	A	630 A	1 000 A	10 000 A	10 000 A
LG1051	80 A	230 V~	500 mA	A	800 A	1 000 A	10 000 A	10 000 A
LG1052	100 A	230 V~	500 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3334	16 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1066	25 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1067	40 A	230 V~	100 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1068	63 A	230 V~	100 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1069	80 A	230 V~	100 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1070	100 A	230 V~	100 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A


LG3335	16 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1071	25 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1072	40 A	230 V~	300 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
4115 84	63 A	230 V~	300 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1073	80 A	230 V~	300 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1074	100 A	230 V~	300 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A

LG3336	16 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1075	25 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1076	40 A	230 V~	500 mA	A-S	500 A	1 000 A	10 000 A	10 000 A
LG1077	63 A	230 V~	500 mA	A-S	630 A	1 000 A	10 000 A	10 000 A
LG1078	80 A	230 V~	500 mA	A-S	800 A	1 000 A	10 000 A	10 000 A
LG1079	100 A	230 V~	500 mA	A-S	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



Signature: **Julien GAUTHIER**
 Certification Officer

ANNEX

Reference DX ³ series	In	Un	IΔn	Type	Im	IΔm	Inc	IΔc
----------------------------------	----	----	-----	------	----	-----	-----	-----

References for Brazilian and Mexican market

LG3383	16 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3384	25 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3385	40 A	127/220 V~	30 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3386	63 A	127/220 V~	30 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG3387	80 A	127/220 V~	30 mA	AC	800 A	1 000 A	10 000 A	10 000 A

LG3389	16 A	127/220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3390	25 A	127/220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3391	40 A	127/220 V~	300 mA	AC	500 A	1 000 A	10 000 A	10 000 A
LG3392	63 A	127/220 V~	300 mA	AC	630 A	1 000 A	10 000 A	10 000 A
LG3393	80 A	127/220 V~	300 mA	AC	800 A	1 000 A	10 000 A	10 000 A
LG3394	100 A	127/220 V~	300 mA	AC	1 000 A	1 000 A	10 000 A	10 000 A

LG3381	16 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 22	25 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 23	40 A	127/220 V~	30 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 24	63 A	127/220 V~	30 mA	A	630 A	1 000 A	10 000 A	10 000 A
4118 25	80 A	127/220 V~	30 mA	A	800 A	1 000 A	10 000 A	10 000 A
4118 26	100 A	127/220 V~	30 mA	A	1 000 A	1 000 A	10 000 A	10 000 A

LG3382	16 A	127/220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 27	25 A	127/220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 28	40 A	127/220 V~	300 mA	A	500 A	1 000 A	10 000 A	10 000 A
4118 29	63 A	127/220 V~	300 mA	A	630 A	1 000 A	10 000 A	10 000 A
4118 30	80 A	127/220 V~	300 mA	A	800 A	1 000 A	10 000 A	10 000 A
4118 31	100 A	127/220 V~	300 mA	A	1 000 A	1 000 A	10 000 A	10 000 A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 11/07/2023



Signature: **Julien GAUTHIER**
 Certification Officer

ANNEX

Characteristics	Values
Independent of line voltage	yes
Rated voltage	230 V~ and 127/220V~ for dual voltage products
Rated frequency	50 Hz
Rated current	16A, 25A, 40A, 63A, 80A, 100A
Rated residual operating current	0.010, 0.030, 0.100, 0.300, 0.500 A
Type	AC – AC-S – A – A-S
Delay time	without, with (type S)
Nature of supply	~
Number of poles	2
Rated insulation voltage	250 V
Rated impulse withstand voltage, Uimp (V)	4 000V
Breaking and making capacity	500 A, 630 A, 800 A, 1000 A
Rated residual making and breaking capacity	1 000 A
Rated residual operating current	10 000 A
Rated conditional residual short-circuit current	10 000 A
Grid distance (short-circuit tests)	35 mm
IP degree	IP20
Material group	II
Method of installation	panel board, distribution board, on rail
Type of terminals	pillar terminal



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 11/07/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 488 263 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer