

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Box for accessories

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCELEGRAND MAGYARORSZAG VILLAMOSSAGI
RENDSZEREK ZRTIPARTELEPI UT 14 PF 10
6600 SZENTES - HUNGARY Additional Information on page 2

See Annex



/

Series : MODUL'UP

References : 0 885 00 (See Annex)

 Additional Information on page 2

IEC 60670-1:2015

161897-738123

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 17/02/2020

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 124
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien Gauthier
Certification Officer

ANNEX

REFERENCE	Depth (mm)	Dimensions (mm)	Specificity
0 885 00	50	Φ 79	Universal box for Plug & Play fonctions

Nature of their material.	Insulating	
Method of installation.	Flush:	hollow ceilings
Type of inlets (outlets)	With inlets for plain or corrugated conduits.	
Clamping means.	Without clamping means.	
Minimum and maximum temperatures during installation.	-5°C to +60 °C	
Boxes and enclosures for hollow walls and the like.	Degree of protection of the part mounted in the hollow	IP20
Arrangements to fix the accessories to the boxes.	Boxes destined to receive another fixing means	
Terminal	2x1,5mm ²	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

Date: 17/02/2020

ANNEX

Accessories

References	Description
0 885 20	DCL cover & hook
0 885 25	Kit DCL : Universal box + DCL cover & hook + screw lampholders type E27 & plug
0 885 24	Kit 25 DCL
0 885 26	Kit DCL + spot

Classification DCL

Rated insulation voltage	250V~
Rated insulation current	6A
Method of installation	For fixed installation
Type of terminals	Plug in terminals
Method of installation	Flush type
Assembly process according to design	Type A
Degree of protection	IP20



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 17/02/2020

