

JPTUV-153013

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

Customer's Testing Facility (CTF) Stage used

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Uninterruptible Power Systems

LEGRAND FRANCE

128 AVENUE DU MARECHAL

DE LATTRE DE TASSIGNY, 87045 LIMOGES CEDEX, France

Delta Electronics, Inc.

3, Tungyuan Road,

Chungli Industrial Zone, Taoyuan City 32063 Taiwan

See additional page(s)

UPS I/P: 10; AC 200/ 208/ 220/ 230/ 240V; 50/60Hz; 7.98/ 7.67/ 8.06/ 7.71/ 7.39A; Class I
UPS O/P: 10; AC 200/ 208V; 50/60Hz; 6.75/ 6.49A; 1350VA; 945W; AC 220/ 230/ 240V; 50/60Hz; 6.82/ 6.52/

6.25A; 1500VA; 1050W

legrand

UPS KEOR SPE 1U RACK 3 110 68

TEC 62040-1:2017+A1

CN23YBWN

This CB Test Certificate is issued by the National Certification Body



2023-10-03

TÜV Rheinland Japan Ltd. Global Technology Assessment Center

4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan

Phone + 81 45 914-3888 Fax + 81 45 914-3354 Mail: info@jpn.tuv.com Web : www.tuv.com

Signature:

Dipl.-Ing. Th. Illing

Date:





JPTUV-153013

Page 2 of 2

- Delta Electronics (Jiangsu) Ltd. 215200, No.1688, Jiangxing East Road, Wujiang Economic and Technological Development Zone Suzhou City, Jiangsu Province, P.R. China
- 2. Delta Electronics India Private Limited
 SEZ Unit
 SY No.16/1b2b(Part) & 16/1b2a(Part),
 Plot No.1, Industrial Park,
 Kurubarapalli Village, Krishnagiri, Tamilnadu, 635115, India
- 3. Delta Electronics (Dongguan) Co., Ltd. No.33, Pantao Road, Shijie Town, Dongguan, Guangdong 523308, P.R. China

Additional information (if necessary)

Report Ref. No. : CN23YBWN 001

M. May

Date: 2023-10-03 Signature: Dipl.-Ing. Th. Illing