

IEC**IECEE**

Ref. Certif. No.

FR_702362/M2**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone
516001 Huizhou
Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX- FRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone
516001 Huizhou, Guangdong - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_702362/A2 dated 16/09/2019. Update the list of product references , Change name and address of applicant, manufacturer and factory

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-ESH-P22011264

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €

RCS Nanterre B 408 363 174

33 avenue du Général Leclerc

F - 92266 FONTENAY AUX ROSES

Signature:  **Julien GAUTHIER**
Certification Officer

Date: 05/05/2022

ANNEX

References, ratings and main characteristics:

RATING AND MAIN CHARACTERISTICS

Type reference	Characteristic	With cover plate	Color of cover
281126	16A 250V~ 2P+E socket	Yes	White
283126		No	Silver
283326		No	Pearl
283526		No	Dark silver
282126		No	Matt black
617656	16A 250V~ 2P+E socket	Yes	White
617756		Yes	Drake grey
617856		Yes	Ivory
618056	16A 250V~ 2P+E socket	Yes	White


CLASSIFICATION


standard Sheet:	Standard sheet III of CEE 7
rated current (A)	16A
rated load (W)	-
rated voltage (V)	250V
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	See the table above
socket-outlets	
multiple socket-outlets	
number of socket-outlets	16A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
plugs:	
class of equipment	-
entry of cable	-



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/05/2022



Signature: 
Julien GAUTHIER
 Certification Officer