



Certificate of Conformity

LOVAG-Certificate No.: IT 20.031
Page 1 of 3

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate



Apparatus Low-voltage busbar trunking system

1000V (U_e) – 1000V (U_i) – 12kV (U_{imp}) – 50/60Hz – 4000A (I_{nA}) – 150kA, 1s (I_{cw}) – IP55/IP65

Designation Type : XCP-HP 4000A AI (4C,5C Type1,2,3)

Manufacturer : BTICINO SPA – LEGRAND GROUP

Via XXV Aprile n°10, 25080 Castrezzzone-Muscoline (BS), Italy.

Applicant : BTICINO SPA – LEGRAND GROUP

Viale Borri n°231, 21100 Varese (VA), Italy.

Verified by ACAE Laboratory:

IB01/LAM Varese (Italy)

IZ01 Castrezzzone di Muscoline BS (Italy)

IV01 Budapest (Hungary)

CSI Bollate MI (Italy)

The apparatus, constructed in accordance with the description mentioned in the Reports listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 61439-6 (2012-05) and EN 61439-6 (2012-08).

The results are shown in the Reports in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer.



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Responsible Certification Body: ACAE
Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Authorized Signature Virginio Scaroni
Date: 2020.06.29



Certificate of Conformity

LOVAG-Certificate No.: IT 20.031
Page 2 of 3

Standard IEC 61439-6 Subclause	TEST	Test Report No.
10.2.2	Resistance to corrosion severity test A	1504—IP *
10.2.3.1	Thermal stability test Bb	1504—IP *
10.2.3.2	Resistance to abnormal heat and fire due to internal electric effects	1504—IP *
10.2.6	Protection against mechanical impact IK10	1749-1
10.2.7	Marking	1504—IP *
10.2.101	Ability to withstand mechanical loads heavy loads	1749-1
10.101	Resistance to flame-propagation	0226\DC\REA\19_2 *
10.3	Degree of protection of assembly IP55 and IP65	1504—IP *
10.4	Clearances and creepage distances	1749-1
10.5	Protection against electric shock and integrity of protective circuits 90kA -1s	11264/VNL
10.9.2	Power-frequency withstand voltage	1749-1
10.9.3	Impulse withstand voltage Uimp 12kV	1749-1
10.10	Temperature-rise limits	1749-1
10.11	Short-circuit withstand strength 150kA – 1s	11264/VNL
10.13	Mechanical strength/operation	Not applicable



* The tests were carried-out on types which are representative of the product under certification.



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Responsible Certification Body: ACAE
Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Virginio Scaroni

Authorized Signature: Virginio Scaroni
Date: 2020.06.29



Certificate of Conformity

LOVAG-Certificate No.: IT 20.031
Page 3 of 3

This document includes:

Reference table tests/products file n.1749
Issue Date : 2020.05.21
Test Reports No.: 1749-1
Issue Date : 2020.03.05
Test Reports No.: 11264/VNL
Issue Date : 2020.03.03
Test Reports No.: 1504-IP
Issue Date : 2019.05.20
Test Reports No.: 0226\DC\REA\19_2
Issue Date : 2019.03.11



PRD N°070B

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Responsible Certification Body: ACAE
Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Authorized Signature: Virginio Scaroni
Date: 2020.06.29