

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Plugs, socket-outlets and couplers for industrial purposes
Name and address of the applicant	LEGRAND FRANCE 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Models Hypra 32A References : see annex
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_701476 dated 14/09/2017, update of test report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012 IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	169087-756208

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 28/01/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15,745,984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

DIVISION INDUSTRIE, ZI DES COUTURES, 519 RUE JULES FERRY
02120 GUISE
FRANCE

LEGRAND FRANCE

670 route de Tendos
76690 FONTAINE LE BOURG
FRANCE



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 28/01/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX (Continued)


References, ratings and main characteristics:

Appliance Inlet						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Metallic	0 528 62	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 528 72	0 530 86
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 73	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 528 63	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 528 73	0 530 90
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 528 64	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 528 74	0 530 91

Bended plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Metallic	0 527 72	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 62	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 63	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 62	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 529 73	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 63	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 529 74	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 64	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: **Julien Gauthier**
Certification Officer

Date: 28/01/2021

ANNEX (Continued)

Connector						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Rubber	0 525 81	
32A	2P+E	100/130 V~	50/60Hz	4h	Plastic	0 519 82	
32A	3P+E	100/130 V~	50/60Hz	4h	Plastic	0 523 72	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 82	0 530 76
32A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 527 92	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 83	0 530 77
32A	3P+E	200/250 V~	50/60Hz	9h	Rubber	0 527 93	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Plastic	0 527 84	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Rubber	0 527 94	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 82	
32A	2P+E	380/415 V~	50/60Hz	9h	Rubber	0 529 92	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 83	0 530 80
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 529 93	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 84	0 530 81
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 529 94	
32A	3P+E	440/460 V~	50/60Hz	11h	Plastic	0 523 52	
32A	3P+E	480/500 V~	50/60Hz	7h	Plastic	0 523 62	

Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 02	
32A	3P+E	200/250 V~	50/60Hz	9h	Metallic	0 527 13	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 03	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 529 13	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 03	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 529 14	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 04	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Julien Gauthier
Certification Officer

Date: 28/01/2021

ANNEX (Continued)

Straight Plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Plastic	0 525 21	
32A	2P+E	100/130 V~	50/60Hz	4h	Plastic	0 519 42	
32A	3P+E	100/130 V~	50/60Hz	4h	Plastic	0 523 71	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 42	0 530 56
32A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 527 52	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 43	0 530 57
32A	3P+E	200/250 V~	50/60Hz	9h	Rubber	0 527 53	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Plastic	0 527 44	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Rubber	0 527 54	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 42	
32A	2P+E	380/415 V~	50/60Hz	9h	Rubber	0 529 52	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 528 43	
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 528 53	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 43	0 530 60
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 529 53	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 528 44	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 44	0 530 61
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 528 54	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 529 54	
32A	3P+E	440/460 V~	50/60Hz	11h	Plastic	0 523 51	
32A	3P+E	480/500 V~	50/60Hz	7h	Plastic	0 523 61	



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Certification Officer

Date: 28/01/2021

ANNEX (End)


Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Plastic	0 525 01	
32A	3P+T	100/130 V~	50/60Hz	4h	Plastic	0 523 70	
32A	2P+T	200/250 V~	50/60Hz	6h	Metallic	0 527 32	
32A	3P+T	200/250 V~	50/60Hz	9h	Metallic	0 527 33	
32A	2P+T	380/415 V~	50/60Hz	9h	Metallic	0 529 32	
32A	3P+T	380/415 V~	50/60Hz	6h	Metallic	0 529 33	
32A	3P+N+T	380/415 V~	50/60Hz	6h	Metallic	0 529 34	
32A	3P+T	440/460 V~	50/60Hz	11h	Plastic	0 523 50	

Main characteristics :

Type of accessory	- Socket outlet - Plugs - Connectors
Rated operating voltage:	2P : 20/25 V~ 2P+E : 100/130 V, 200/250 V, 380/415 V 3P+E : 100/130 V, 200/250 V, 380/415 V, 440/460 V, 480/500 V 3P+N+E: 200/250 V, 200/346 V to 240/415 V
Rated current:	32 A
Degree of protection:	IP44, IP55, IP66/67
Standard sheet:	2-I and 2-II
Position of earthing contact:	4h, 6h, 7h, 9h, 11h
Keyway position:	With / without
Type of terminal:	Screw-type
Plugs and connectors	
Type of cable exit:	Straight - angled
Appliance inlet and socket-outlet	
Type of installation:	panel type – surface-type



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: *Julien Gauthier*
Julien Gauthier
Certification Officer

Date: 28/01/2021