

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Three and Four poles Switch Disconnecter

Name and address of the applicant

LEGRAND FRANCE  
128 avenue du Maréchal de Lattre de Tassigny 87045 Limoges  
Cedex (France)

Name and address of the manufacturer

BTICINO SpA - Legrand Group  
Viale Borri 231, Varese 21100  
Italy

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue=220-690V (50.0-60.0Hz) – Ie=630A  
Icw=15.00kA (1.00s) – Icm=30.0kA, Pattern No. 3 and 4

Trademark (if any)

Legrand

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DPX-IS 630

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2026730STO-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, SwedenSignature: 

Date: 22 December, 2021

Quan Li

**Factories**

Bticino S.p.a. – Via dei Folzoni, 5 – 24052, Azzano, San Paolo, Bergamo (Italy)

S.M.E.A Srl, Via Ghandi, 8 Treviolo, Bergamo 24048, Italy

**Additional information**

Characteristics:

Voltage ratings  $U_e=220-690V$  (50-60Hz)

Rated current  $I_e=250A$

$U_{imp} = 8kV$      $U_i = 800V$

Utilization Category: AC23A

$U_e$ (V)	$I_e$ (A)	$I_{cm}$ (kA)	$I_{cw}$ (1s) (kA)
690	630	30	15

Utilization Category: AC22A

$U_e$ (V)	$I_e$ (A)	$I_{cm}$ (kA)	$I_{cw}$ (1s) (kA)
690	630	30	15

Date: 22 December, 2021

Signature: 