

IEC

IECEE

Ref. Certif. No.

FR_718683

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

LEGRAND POLSKA SP. Z O.O.
UL. Waryńskiego 20
57-200 Ząbkowice Śląskie
POLAND

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF3

Model / Type Ref.

Serie : PLEXO S
See Annex

Additional information (if necessary may also be reported on page 2)

/ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2002 +A1:2011
IEC 60670-24:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

PR006020

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/03/2024



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

ANNEX

Mechanisms

Trademark	References Color : grey	Number of modules	Rated current (A)	Dimensions (mm)	Reference of integrated terminal block	Icc terminal block (kA)	Type of terminals
LEGRAND	6 018 02	2	25	170 x 75 x 106	Without	/	/
LEGRAND	6 018 84	4	32	200 x 141 x 106	Earth + neutral A025996AA	6	screw
LEGRAND	6 018 86	6		200 x 177 x 106	Earth + neutral A25997AA	6	screw
LEGRAND	6 018 88	8		200 x 213 x 106		6	screw
LEGRAND	6 018 92	12	63	200 x 285 x 106	Earth + neutral A025998AA	6	screw
LEGRAND	6 018 94	2x12		350 x 285 x 106	Earth + neutral A025999AA	6	screw

Characteristics

Standard sheet	
Rated insulation voltage (V)	400V~
Rated current (A)	See Table
Nature of their material	Insulating
Method of installation	Surface mounting on (Combustible or not) walls , ceilings , floors or furniture Placement on suitable for all types of installation except into concrete
Type of inlets (outlets)	Without inlets. Inlet openings will be made during installation
Clamping means	Without clamping means
Minimum and maximum temperatures during intallation	- 5°C to 60°C
Empty closure	PD enclosure for Legrand
Protection degree	IP65
IK	7



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/03/2024



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 893 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer