



Ref. Certif. No.

SE-96193

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket outlet with USB charger, panel type

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MA, RECHAL DE LATTRE DE TASSIGNY, 8 7 0
4 5 L IMOGES CEDEX, FRANCE

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

DONGGUAN ROCOM ELECTRIC COMPANY LTD
No.5 HONG'AN ROAD, WU SHA DISTRICT, CHANG'AN TOWN,
DONGGUAN CITY, GUANGDONG PROVINCE, CHINA

Ratings and principal characteristics

16A, 250V~, IP20 (after built in)

Trademark (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

0 775 95

Additional information (if necessary may also be reported on page 2)

16A 250V~, IP20, class I, panel-type, single-way socket-outlet comply with standard sheet CEE 7/V, with shutter, with screwless terminals, with USB charger (Output: 5V DC 3A max), with spring device under engagement surface.

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002 + A1 + A2

As shown in the Test Report Ref. No. which forms part of this Certificate

171101663SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 20 November 2019

intertek

Signature:

Hyden Li