



Ref. Certif. No.

HU-001259-A4

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet

Name and address of the applicant

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentes, Hungary

Name and address of the manufacturer

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentes, Hungary

Name and address of the factory

Note: When more than one factory, please report on page 2

Legrand Magyarország Villamossági Rendszerek Zrt.
Ipartelepi út 14.
H-6600 Szentes, Hungary

Ratings and principal characteristics

250V~, 16A;
Standards Sheet: IEC 60083:1975 St. Sh. C2a;
with side-earthing contact; rewirable
(refer to Test Report for further details)

Trademark (if any)

 **Legrand**

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Design: „Mosaic”
(See page 2 of this Certificate for further details)

Additional information (if necessary may also be reported on page 2)

This Certificate is amendment No.4 to CBTC ref. No. HU-001259, dated 2014-02-18 and it is issued to add new model variant with new reference number
(See details in Test Report)

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002 + AMD1:2006 + AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

28220817 007

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

Date: 2017-11-23

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:



Gabor Kassai



Ref. Certif. No.

HU-001259-A4

New model variant:

Ref. No.	Description	Colour
079355	2P+E socket-outlet with screwless terminals, side earthing contacts and shutters, 45° Ref. No. of cover: ED04554	black

Additional information (if necessary)



Date: 2017-11-23

TÜV Rheinland InterCert Kft., Division MEEH
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:



Gabor Kassai