



Ref. Certif. No.

FR_707919

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switches for fixed electrical installations combined with switched socket-outlet

Name and address of the applicant

TCL-Legrand International Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - China

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

 , legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

MALLIA range
References : See Annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 3

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-19SE0280ACSHP

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:  Julien GAUTHIER
Certification Officer

Date: 26/02/2020

ANNEX

Name and address of the factories:**TCL-Legrand International Electrical(Huizhou) Co., Ltd.**

Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong – CHINA

LEGRAND (BEIJING) ELECTRICAL Co Ltd

N° 4 CHAOQIAN ROAD, CHANGPING DISTRICT KEJIYUANQU, 101214 BEIJING - CHINA

LEGRAND ELECTRIC Ltd

Unit 12 N° 1 Industrial Estate Medomsley Road Conselt, County Durham DH8 6SR - UNITED KINGDOM



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex

www.lcie.fr


Date: 26/02/2020



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174

33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:  Julien GAUTHIER
Certification Officer

REFERENCES - PRINCIPAL CHARACTERISTICS

Reference	Range	Description	Color of enclosure
281075	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	White
281275	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	Silver
282075	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	Matt Black
283275	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	Pearl
281775	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	Champagne
283475	MALLIA	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched with neon)	Dark Silver

Pattern number	2
Contact opening	normal gap
Protection degree	IP20
Method of actuating	rocker
Method of mounting	flush-type
Method of installation	design A
Type of terminals	screw-type (rigid and flexible)
Flexible cable outlet	without
Ratings	45A 250V~
Color	White, Silver, Matt Black, Pearl, Champagne, Dark Silver

Components	Model	Manufacturer	Conformity
Combined 13A switched socket-outlet	281075, 281275, 282075, 283275, 281775, 283475	LEGRAND FRANCE	LCIE test report No. ARLI-19SE0279ACSHP



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: *Julien Gauthier*
Julien GAUTHIER
Certification Officer

Date: 26/02/2020