

IEC**IECEE**

Ref. Certif. No.

FR_719909

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Adaptor

Name and address of the applicant

LEGRAND FRANCE128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

NINGBO BANMEN ELECTRIC APPLIANCE CO., LTD.East Industrial Zone, Guanhaiwei, Cixi City, 315314
Zhejiang Province - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

0 504 61

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR 636148B dated 13/03/2013.
Update further to the evolution of the standard(s)
Update the list of product references Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
IEC 60884-2-5:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P22111814

This CB Test Certificate is issued by the National Certification Body

**LCIE**

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €

RCS Nanterre B 408 363 174

33 avenue du Général Leclerc

F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

Date: 02/09/2024

ANNEX

CLASSIFICATION

standard Sheet:	V (socket-outlet) / VII (plug) of CEE 7
rated current (A)	16 A
rated load (W)	3680 W
rated voltage (V)	250 V~
household voltage (V)	230 V~
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	grey+white
socket-outlets	
multiple socket-outlets	
number of socket-outlets	16A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	portable type
method of installation	-
plugs:	
class of equipment	I
entry of cable	-



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 02/09/2024



Signature:  **Julien GAUTHIER**
 Certification Officer