

IEC

IECEE

Ref. Certif. No.

FR_716289

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed switched socket-outlet
Switched socket-outlets for fixed installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone, 516001 Huizhou
Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



tenby

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
IEC 60884-2-3:2006

As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-ESH-P22071876

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 31/01/2023



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 134
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES
Signature: **Julien GAUTHIER**
Certification Officer

ANNEX

Name and address of the factories:**Legrand Intelligent Electrical (Huizhou) Co., Ltd.**

Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone
516001 Huizhou, Guangdong – CHINA

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK Zrt

IPARTELEPI UT 14 PF 10, 6600 SZENTES - HUNGARY

LEGRAND ELECTRIC Ltd


UNIT 12 N° 1 INDUSTRIALL ESTATE MEDOMSLEY ROAD CONSETT
COUNTY DURHAM, DH8 6SR - UNITED KINGDOM



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 31/01/2023



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
Certification Officer

ANNEX

Product References:

tenby for model 738145A;  for all other models.

REFERENCES - MAIN CHARACTERISTICS

Reference	Range*	Product description	Color of enclosure
572129A	Arteor	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	WHITE
		Made in China	
572629A	Arteor	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	MAGNESIUM
		Made in China	
572229A	Arteor	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	CHAMPAGNE
		Made in China	
572249A	Arteor	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	ALU
		Made in China	
678139A	MOSAIC	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	WHITE
		Made in Hungary	
730073A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	WHITE
		Made in China	
832073A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	BSS
		Made in UK	
832473A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	GOLD
		Made in UK	
832273A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	PSS
		Made in UK	
833073A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	BSS
		Made in UK	
833473A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	GOLD
		Made in UK	
833273A	Synergy	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	PSS
		Made in UK	
738145A	Tenby	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	WHITE
		Made in China	
617666A	LINDBERGH	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	WHITE
		Made in China	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 31/01/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 498 363 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer

ANNEX

Reference	Range*	Product description	Color of enclosure
617766A	LINDBERGH	1G BS 13A SP SWITCHED SOCKET + USB TYPE C	ANTHRACITE
		Made in China	
617866A	LINDBERGH	1G BS 13A SP SWITCHED + USB TYPE C	CHAMPAGNE
		Made in China	
281130AMW	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	MATT WHITE
		Made in China	
281130AMB	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	MATT BLACK
		Made in China	
281130ADS	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	DARK SILVER
		Made in China	
281130ACH	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	CHAMPAGNE
		Made in China	
281130ADB	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	DARK BRONZE
		Made in China	
281130ABA	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	BRUSHED ALUMINIUM
		Made in China	
281130ABB	Mallia senses	1G BS 13A SINGLE POLE SWITCHED SOCKET + USB TYPE C 3A	BRUSHED BLACK
		Made in China	
282483A	GALION	1G BS 13A SWITCHED SOCKET + USB TYPE C CHARGER	WHITE
		Made in China	
282483A-C	GALION	1G BS 13A SWITCHED SOCKET + USB TYPE C CHARGER	MATT BLACK
		Made in China	
282483A-C1	GALION	1G BS 13A SWITCHED SOCKET + USB TYPE C CHARGER	ROSE GOLD
		Made in China	
282483A-C2	GALION	1G BS 13A SWITCHED SOCKET + USB TYPE C CHARGER	CHAMPAGNE
		Made in China	
282483A-C3	GALION	1G BS 13A SWITCHED SOCKET + USB TYPE C CHARGER	DARK SILVER
		Made in China	

* The "Range" denotes applicant's categorization.


 LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 31/01/2023


 LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 483 363 171
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

 Signature:  **Julien GAUTHIER**
 Certification Officer

ANNEX

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	See the table above
socket-outlets	
multiple socket-outlets	13A : 1
number of socket-outlets	
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A (572129A, 572629A, 572229A, 572249A, 678139A, 832073A, 832473A, 832273A, 617666A, 617766A, 617866A, 281130AMW, 281130AMB, 281130ADS, 281130ACH, 281130ADB, 281130ABA, 281130ABB, 282483A, 282483A-C, 282483A-C1, 282483A-C2, 282483A-C3) / design B (738145A, 730073A, 833073A, 833473A, 833273A)
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	unswitched neutral

type of components	manufacturer	Certification
USB charger	Legrand Intelligent Electrical (Huizhou) Co., Ltd.	LCIE test report No. ARLI-ESH-P22071902




LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 31/01/2023



LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 408 363 124
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
 Certification Officer