

IEC**IECEE**

Ref. Certif. No.

FR_717632/A1**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

BAES of evacuation with light-emitting diode NP

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

LEGRAND FRANCE.
1 RUE HENRI FREYSSINET
17140 LAGORD
FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_717632 dated 12/09/2023. Editorial correction

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2020
IEC 60598-2-22:2021


As shown in the Test Report Ref. No. which forms part of this Certificate

17382942- 784812 A Version : 02
17382942- 784812 B Version : 02

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 24/10/2023

Signature: Jérôme REYSSON
Certification Officer

ANNEX

References, ratings and main characteristics:

Characteristics	Values
Type	Bloc à phares Addressable for 6 624 52
Rated voltage	230V
Nature of supply	~
Rated frequency	50/60 Hz
Rated power	6,6W for 6 614 52 - 6 614 54 - 6 624 52 8W for 6 614 53
Class of protection from electric shock	II
IP degree	IP55
IK degree	IK07
Rated lumen output	1000 lm - 2h : 6 614 54 1500 lm - 1h : 6 614 52 and 6 624 52 2500 lm - 1h : 6 614 53
Light source - Emergency mode (emergency lamps) - Type, number	2 x 2 LEDs : 6 614 52 - 6 614 54 - 6 624 52 2 x 4 LEDs : 6 614 53
Battery type	6 614 52 - 6 614 54 - 6 624 52 : NiCd 2 x(4 x 1,2V) / 4Ah BST D4000BT NiCd 2 x(4 x 1,2V) / 4Ah JYH D4000GT-B2*2ML 6 614 53 : NiCd 2x (6 x 1,2V) / 4Ah BST D4000BT NiCd 2x (6 x 1,2V) / 4Ah JYH D4000GT-B3*2ML



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 24/10/2023

