

IEC

IECEE

Ref. Certif. No.

FR\_705863/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Boxes and enclosures for electrical accessories

Name and address of the applicant

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series: BATIBOX\_Flush mounting boxes for dry partitions  
References: See annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_705863 dated 24/07/2019. Updated manufacturing site address and references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015


As shown in the Test Report Ref. No. which forms part of this Certificate

23188850-803655

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)



Date: 16/10/2024

Signature: Julien GAUTHIER  
Certification Officer

## ANNEX

**Name and address of the factories:****LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

**ERP ELBROMPLAST**

STRADA SIEMENS NR 3  
300704 TIMISOARA  
ROMANIA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 16/10/2024



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:   
**Julien GAUTHIER**  
Certification Officer

## ANNEX


**References, ratings and main characteristics:**
**Mechanisms**

Reference	Capacity Gang	Capacity modules	Depth (mm)	Dimension (mm)	Distance between centres (mm)	Making up
0 800 40	-	1	40	35,5 x 76,5	-	
0 905 39	-	1	40	35,5 x 76,5	-	0 800 40
0 800 41	1	-	40	Ø 67	-	
0 800 06	1	-	40	Ø 67	-	300 x 0 800 41
0 800 08	1	-	40	Ø 67	-	100 x 0 800 41
0 905 41	1	-	40	Ø 67	-	0 800 41
200 186	1	-	40	Ø 67	-	10 x 0 800 41
200 319	1	-	40	Ø 67	-	40 x 0 800 41
391 990	1	-	40	Ø 67	-	0 800 41
0 800 42	2	4/5	40	Ø 67	71	
0 905 42	2	4/5	40	Ø 67	71	0 800 42
0 800 43	3	6/8	40	Ø 67	71	
0 905 43	3	6/8	40	Ø 67	71	0 800 43
0 800 44	4	8/10	40	Ø 67	71	
0 905 44	4	8/10	40	Ø 67	71	0 800 44
0 800 49	-	3	40	71 x 111	-	
0 800 51	1	-	50	Ø 67	-	
391 991	1	-	50	Ø 67	-	0 800 51
0 800 09	1	-	50	Ø 67	-	0 800 51 x 100
0 800 52	2	4/5	50	Ø 67	71	
0 800 53	3	6/8	50	Ø 67	71	
0 800 54	4	8/10	50	Ø 67	71	
0 800 61	1	-	60	Ø 67	-	
1 893 52	2	-	50	Ø 67	57	
1 893 53	3	-	50	Ø 67	57	
0 893 48	1	-	40	Ø 85	-	
0 919 85	1	-	40	Ø 85	-	0 893 48



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 16/10/2024



Signature: **Julien GAUTHIER**  
 Certification Officer

## ANNEX

### Classification

Nature of their material	Insulating
Method of installation	Flush in hollow walls, hollow ceilings, hollow floors or furniture
Type of inlets (outlets)	With inlets for plain or corrugated conduits
Clamping means	Without clamping means
Minimum and maximum temperatures during installation	- 5°C to 60°C
Degree of protection of the part mounted inside the hollow walls	IP20
Arrangements to fix accessories to the boxes	Boxes supplied with screws

### Accessories

References	Designation / Function
0 897 48	Long screw 40 mm
0 800 71	Removable divider for multi-gang boxes depth 40 mm
0 800 72	Removable divider for multi-gang boxes depth 50 mm



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 16/10/2024



Signature:  **Julien GAUTHIER**  
 Certification Officer