



Ref. Certif. No.

JPTUV-152965

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Power Supply
Name and address of the applicant	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATRE DE TASSIGNY, 87045 LIMOGES CEDEX, France
Name and address of the manufacturer	Delta Electronics, Inc. 3, Tungyuan Road, Chungli Industrial Zone, Taoyuan City 32063 Taiwan
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	Input : 1Ø; AC 200/ 208/ 220/ 230/ 240V; 50/60Hz; 3.99/ 3.84/ 4.03/ 3.85/ 3.69A; Class I Output: 1Ø; AC 200/ 208V; 50/60Hz; 3.38/ 3.25A; 675VA; 472.5W; 1Ø; AC 220/ 230/ 240V; 50/60Hz; 3.41/ 3.26/ 3.13A; 750VA; 525W
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	UPS KEOR SPE 1U RACK 3 110 65
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN237ED8 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2023-10-03

Signature:

Dipl.-Ing. Th. Illing

1. Delta Electronics (Jiangsu) Ltd.
215200, No.1688, Jiangxing East Road,
Wujiang Economic and Technological
Development Zone
Suzhou City, Jiangsu Province, P.R. China
2. Delta Electronics India Private Limited
SEZ Unit
SY No.16/1b2b(Part) & 16/1b2a(Part),
Plot No.1, Industrial Park,
Kurubarapalli Village, Krishnagiri, Tamilnadu, 635115, India
3. Delta Electronics (Dongguan) Co., Ltd.
No.33, Pantao Road, Shijie Town,
Dongguan, Guangdong 523308,
P.R. China
4. Delta Electronics (Dongguan) Co., Ltd.
Southwest Branch
No.33, Pantao Road, Shijie Town,
Dongguan, Guangdong 523308,
P.R. China

Additional information (if necessary)

Report Ref. No. : CN237ED8 001



Date: 2023-10-03

Signature:

Dipl.-Ing. Th. Illing