

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch

Switches for fixed electrical installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone Huizhou Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone Huizhou Guangdong - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_706749/M1 dated 04/12/2020
Change applicant and factory name
Update the list of product references Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-ESH-P20121708

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 12/04/2021

Signature: Jérôme REYSSON
Certification Officer

ANNEX

References, ratings and main characteristics:

Reference	Range*	Description	Color of enclosure
617678	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	White
617778	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	Anthracite
617878	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	Ivory
281075MW	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Matt white
281075MG	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Matt grey
281075MB	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Matt black
281075DS	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Dark sliver
281075CH	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Champagne
281075DB	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Dark bronze
281075BA	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Brushed aluminium
281075BB	Mallia senses	Cooker Control unit 2 gang (45A double pole switch with neon + 2P+E 13A British Standard Double Pole switched + neon)	Brushed black

* The "range" denotes applicant's categorization.



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 12/04/2021

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 362 744
F - 92266 FONTENAY AUX ROSES

Signature **Jerôme REYSSON**
Certification Officer



Ref. Certif. No.

FR_706749/M2

ANNEX


Pattern number	2
Contact opening	normal gap
Protection degree	IP20
Method of actuating	rocker
Method of mounting	flush-type
Method of installation	design A
Type of terminals	screw-type (rigid and flexible)
Flexible cable outlet	without
Ratings	45A 250V~
Color	White, Anthracite, Ivory, Matt white, Matt grey, Matt black, Dark silver, Champagne, Dark bronze, Brushed aluminium, Brushed black

Components	Model	Manufacturer	Conformity	Validity
Combined 13A switched socket-outlet	617678, 617778, 617878, 281075MW, 281075MG, 281075MB, 281075DS, 281075CH, 281075DB, 281075BA, 281075BB	Legrand France	LCIE test report No. ARLI-ESH-P20121828	Valid



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 12/04/2021



Signature: Jérôme Bérillon
Certification Officer