



# Compliance Statement

**Unscreened Class D / Category 5e**

**ISO/IEC, EN & ANSI/TIA**

**Two Connector Permanent Link**

**Legrand**


**128 Avenue de Lattre de Tassigny,  
87045 Limoges Cedex, France**

**Compliance Statement No. 0473-3P-1220421**

*This type of Class D / Category 5e Unscreened Two Connector Permanent Link has been tested by 3P Third Party Testing. The testing has shown compliance with the Class D electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 5e electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested permanent link samples, consisting of the listed components. The Compliance Statement is valid until 7 October 2024.*

<i>Cables:</i>	<i>Horizontal Cable (30 - 90 m),</i>	<i>P/N 6 327 15</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack,</i>	<i>P/N LK01</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>


Hoersholm, 7 April 2022

  
Peter Freiberg Kaas  
Test Responsible

**3P Third Party Testing ApS**  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 7 April 2022

  
Jens Rytter Petersen  
General Manager