

SG PSB-IT-00190

MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT SYSTEM FOR (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product Switches

(Electronic, Light Dimmer)

Name and address of the applicant Legrand Intelligent Electrical

(Huizhou) Co., Ltd.

Bldg. B1-B3, East No.39 Hechang 6th Rd. HZZK Hi-tech Industrial Development Zone

516007 Huizhou, Guangdong PEOPLE'S REPUBLIC OF CHINA

Legrand Intelligent Electrical (Huizhou) Co., Ltd. Name and address of the manufacturer

> Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, 516007 Huizhou, Guangdong, PEOPLE'S REPUBLIC

OF CHINA

Legrand Intelligent Electrical (Huizhou) Co., Ltd. Name and address of the factory

Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, 516007 Huizhou, Guangdong, PEOPLE'S REPUBLIC

OF CHINA

Ratings and principal characteristics Rated Voltage: 100-240V~

Rated Frequency: 50/60Hz

Rated load: Incandescent lamp, Max.400W/VA,

Min.40W/VA at 240V~;

Max.200W/VA, Min.20W/VA at 100V~

Patter number: 1

Contact opening: Micro-gap Duty type: Continuous

IP class: IP00

Model/type Ref. 730049, 832156, 832157, 832356, 832357, 832556,

832557, 833157, 833356, 833357, 833556, 833557.

A sample of the product was tested and found

to be in conformity with

IEC 60669-1:2017 IEC 60669-2-1:2002

IEC 60669-2-1:2002/AMD1:2008 IEC 60669-2-1:2002/AMD2:2015

IEC 60669-2-5:2013

as shown in the Test Report Ref. No.

which forms part of this certificate

085-210097401-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 111552 0001 Rev. 00

Date. 2021-06-10





SG PSB-IT-00190

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trade mark (Image)



Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 111552 0001 Rev. 00

Date, 2021-06-10

Jir Sharahara I

