


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Socket-outlet for fixed-electrical installations
Name and address of the applicant	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone Huizhou, Guangdong - CHINA
Name and address of the manufacturer	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone Huizhou, Guangdong - CHINA
Name and address of the factory	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone Huizhou, Guangdong - CHINA
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	15 A ; 250 V~ See Annex
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	617650, 617750, 617850, 617050, 617350, 617450
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_706700 dated 29/08/2019. Addition of product references <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	ARLI-ESH-P20091539

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 01/12/2020



Signature: Julien GAUTHIER
Certification Officer

ANNEX

References, ratings and main characteristics:


Reference	Description	Color code of of enclosure
617650	1G BS 15A UNSWITCHED SOCKET	White
617750	1G BS 15A UNSWITCHED SOCKET	Anthracite
617850	1G BS 15A UNSWITCHED SOCKET	Ivory
617050	1G BS 15A UNSWITCHED SOCKET	White
617350	1G BS 15A UNSWITCHED SOCKET	Dark grey
617450	1G BS 15A UNSWITCHED SOCKET	Brown

CLASSIFICATION

standard Sheet:	BS 546
rated current (A)	15A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	White, Anthracite, Ivory
socket-outlets	
multiple socket-outlets	
number of socket-outlets	15A: 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Signature: *Julien GAUTHIER*
Certification Officer

Date: 01/12/2020