



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +39035 4175244 fax. +39035 4534662 e-mail: acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. IT 11.028

Apparatus

Four pole modular circuit breaker 400 V (U_o) - 500 V (U_i) - 32 A (I_n/I_{the})
50/60 Hz - I_{cs} 12 kA at 400 V - I_{cu} 16 kA at 400 V with short circuit and overload
release $I_n = 32$ A

Designation

DX³ 10000 A/16 kA

Manufacturer or responsible vendor

Legrand SNC - 128, Av. du Maréchal-de-Lattre-de-Tassigny - 87045 Limoges
Cedex (France)

Tested for: Legrand SNC

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned
in the Test Report listed on this Certificate has been subjected to the
series of proving tests in accordance with IEC 60947-2 (2009) Edition 4.1

Test sequence: II and III

This Certificate applies only to
the apparatus tested. The
responsibility for conformity of
any apparatus having the
same designation with that
tested rests with the
manufacturer or responsible
vendor.

This certificate has been pre-
pared according to LOVAG
(Low Voltage Agreement
Group) Objectives and
Operating Principles of mutual
recognition.

The responsible certification
body as member of LOVAG
issues a Certificate of Confor-
mity with the above mentioned
Standard(s) following the
exclusive use of LOVAG Test
Instructions wherever
applicable.

Only integral reproduction of
this Certificate or
reproductions of this page
accompanied by any page(s)
on which are stated the tests
performed and the assigned
rated characteristics of the
apparatus Tested, are
permitted without written
permission from the LOVAG
Signatory responsible for this
Certificate.

Expiry of this certificate
see ACAE certification
scheme.

The results are shown in the Test Report in accordance to LOVAG. The values
obtained and the general performance are considered to comply with the
above Standard(s) and to justify the characteristic assigned by the manufacturer
as stated below.

Suitable for isolation

Utilization category A

U_e 400 V	a.c. 50/60 Hz	I_n 32 A	I_{cs} 12 kA
U_e 400 V	a.c. 50/60 Hz	I_n 32 A	I_{cu} 16 kA

This document includes Report No.: 11.032-1

Issue Date: 2011.04.13

Responsible Certification Body: ACAE



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Mauro Marchi

Authorized Signature

Date: 2011.05.02