

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR  
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switched socket outlet, flush type
Name and address of the applicant	Legrand (Beijing) Electrical Co., Ltd. No.4 Chaoqian Road, Changping Kejiyuanqu, Beijing, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	13A, 250V~, IP20, Class I
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	281113, 283113, 283313, 283513, 283913, 282113, 281115, 283115, 283315, 283515
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1+A2 IEC 60884-2-3:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	181000125SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 30 November 2018

intertek

Signature:

Hyden Li



**Additional information (if necessary)**

Flush type, rewirable, with two way Type G outlets (configuration of BS 1363-2), with shutter, with single pole switch, with or without indicator lamp, with plastic front cover, see below for details:

## Model list:

- 281113: without indicator lamp, with white cover.
- 283113: without indicator lamp, with silver cover.
- 283313: without indicator lamp, with pearl cream cover.
- 283513: without indicator lamp, with darkgrey cover.
- 283913: without indicator lamp, with champ cover.
- 282113: without indicator lamp, with matt black cover.
- 281115: with indicator lamp, with white cover.
- 283115: with indicator lamp, with silver cover.
- 283315: with indicator lamp, with pearl cream cover.
- 283515: with indicator lamp, with darkgrey cover

Date: 30 November 2018

Signature:

