

# LICENCE

No. 19609 replaces No.12515, 12517, 12516

Issued to:  
 Applicant:  
**Legrand Group Belgium N.V.**  
 Kouterveldstraat 9, Ind. Zone  
 1831 DIEGEM  
 Belgium

Licensee:  
**Legrand Group Belgium N.V.**  
 Kouterveldstraat 9, Ind. Zone  
 1831 DIEGEM  
 Belgium



Product : switches (for fixed installations)  
 Trade name(s) : LEGRAND  
 Type(s)/model(s) : Appareillage Saillie, Série Oteo ( see appendix )

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 178


SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on : 17/08/2015

  
 ir. C. Lana,  
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed  
 This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	switches (for fixed installations)
Trade name(s)	:	LEGRAND
Type(s)/Model(s)	:	Appareillage Saillie, Série Oteo ( see appendix )
rated current (In)	:	6A, 10 AX
rated voltage (Un)	:	250 V
nature of supply	:	AC
method of actuating	:	rocker, push-button cord operated
contact opening (gap)	:	normal
protection against harmful ingress of water	:	ordinary
type of terminals	:	screw-type
protection against electric shock	:	enclosed
method of mounting	:	surface-type
method of installation	:	type A
markings	:	are shown on the body

### Additional information

See Appendix

## TESTS

### Test requirements

NBN EN 60669-1:1996 + A1:1997 + A29:1998  
NBN EN 60669-1 based on EN 60669-1:1999 + A1:2002 + A2:2008

### Test results

The test results are laid down in certification file ref.620532/01



**Remarks**

This certificate is based on certificates ref. CB FR 639996B & CB FR640022 and test reports ref. 120104-639999 & 120102-640025


**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Zanotto Luigi - 17/08/2015

Department Manager,  
Product Certification :

Certification Manager

 2015-09-17

**FACTORY LOCATION(S)**

Legrand SNC  
128, avenue du Maréchal de Lattre de Tassigny  
87045 LIMOGES CEDEX  
France

**Products references Series Oteo.****Switches**

Reference	Pattern Nr.	Ratings	Method of actuating	Pilot light
86106	1	6A/250V~	Push-button	No
86105	1	6A/250V~	Push-button	Yes
86109	6	6A/250V~	Push-button	Yes
86121	2 x 1	6A/250V~	Push-button	No
86101	6	10AX/250V~	Rocker	No
86117	6	10AX/250V~	Rocker	Yes
86119	6	10AX/250V~	Cord operated	No
86120	2 x 6	10AX/250V~	Rocker	No
86103	2	10AX/250V~	Rocker	No
86118	2	10AX/250V~	Rocker	Yes
86104	7	10AX/250V~	Rocker	No

**Surface mounting frames**

Reference	Description
86091	1 gang
86092	2 gang
86093	3 gang