



Ref. Certif. No.

SE-86036M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	Fixed socket-outlet (Flush type)
Name and address of the applicant	Legrand (Beijing) Electrical Co. Ltd No. 4 Chaoqian Road, Changping Kejiyuanqu, Beijing, CHINA
Name and address of the manufacturer	Same as above
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	13A, 250V~, IP20, Class I
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	617057, 617257, 617357, 617457, 281133, 283133, 283333, 283533, 283933
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002 + A1 + A2 Standard sheet: type G (Configuration of BS 1363-2) National differences: BS 1363-2:1995 + A4:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	161200605SHA-001, 161200605SHA-001 M1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 21 April 2017



Signature:

Gary Hu



Ref. Certif. No.

SE-86036M1

Additional information (if necessary)

Flush type, rewirable, with one way Type G outlets (configuration of BS 1363-2), with shutters, with USB charger which evaluated according to IEC 60950-1:2005 + A1:2009 + A2:2013 with report no 161001261SHA-001 M1, with plastic cover, with design A construction, all type with same construction, only a little different outer enclosure shape and different cover plate painting colour.

- 617057: White colour
- 617257: Ivory colour
- 617357: Dark grey colour
- 617457: Brown colour
- 281133: white colour
- 283133: silver colour
- 283333: pearl colour
- 283533: dark silver colour
- 283933: champagne

This certificate replaces CB certificate SE-86036, dated 17 February 2017. A new certificate has been issued due to add new type 281133, 283133, 283333, 283533, 283933 which with similar construction as former types, only a little different outer enclosure shape and different cover plate painting colour.

Date: 21 April 2017

Signature: 