



Ref. Certif. No.

HU-002840

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet

Name and address of the applicant

Legrand Magyarország Villamossági Rendszerek Zrt.  
Ipartelepi út 14.  
H-6600 Szentes, Hungary

Name and address of the manufacturer

Legrand Magyarország Villamossági Rendszerek Zrt.  
Ipartelepi út 14.  
H-6600 Szentes, Hungary

Name and address of the factory

LLC Legrand branch Ulyanovskiy  
30 Proezd Inzhenerny, 5.1  
RU-432072 Ulyanovsk, Russia

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

250V~, 16A; IP20  
(see Test Report for further ratings)

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

Design: "FORIX", "QUTEO" and "ARNOULD"  
(See General product information of Test Report for the list of type variants)

Additional information (if necessary may also be reported on page 2)

---

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002 + AMD1:2006 + AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

28251997 001

This CB Test Certificate is issued by the National Certification Body




TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com

Date: 2020-02-19

Signature:



Gabor Kassai