



Ref. Certif. No.

FR\_707222/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Boxes and enclosures for electrical accessories

Name and address of the applicant

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

See Annex

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

series : BATIBOX for ceiling rose unit  
references : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_707222 dated 08/11/2019. Addition of product references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015  
IEC 60670-21:2004 + A1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

24295478-806596

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/10/2025

Signature:

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
33 avenue du Général Leclerc  
92260 FONTENAY-AUX-ROSES

**IEC****IECEE**

Ref. Certif. No.

**FR\_707222/A1****ANNEX****Name and address of the factories:****LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

**LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT**

IPARTELEPI UT 14 PF 10  
6600 SZENTES  
HUNGARY

**LEGRAND FRANCE SILLE LE GUILLAUME**

80 ROUTE D'EVRON  
72140 SILLE LE GUILLAUME  
FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/10/2025

Signature:

  
LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
33 avenue du Général Leclerc  
92260 FONTENAY-AUX-ROSES  
Certification Officer

## ANNEX (continued)

Trademark	Reference Color : Yellow	Reference Color : Grey	Depth ( mm )	Dimension ( mm )	Specifity	DCL cover reference	PRO/DIY	Making Up
LEGRAND	0 892 37		50	Φ 65	Masonry box, with DCL cover	0 895 90	PRO	
	0 892 56		50	Φ 65	Masonry box, with cover		PRO	
	0 893 36		50	Φ 67	Hollow walls box, with cover		PRO	
	0 893 37		50	Φ 67	Hollow walls box, with DCL cover	0 895 90	PRO	
	0 893 77	0 893 77L	50	Φ 67	Hollow walls box (Ecobatibox), with DCL cover	0 895 90	PRO	
	0 893 60	0 893 60L	50	Φ 67	Hollow walls box (Ecobatibox), with DCL cover	0 895 90	PRO	0 893 77
	0 905 15	0 905 15L	50	Φ 67	Hollow walls box (Ecobatibox), with DCL cover	0 895 90	DIY	0 893 77
	0 905 65		50	Φ 67	Hollow walls box, with cover		DIY	0 893 36
	0 905 67		50	Φ 67	Hollow walls box, with DCL cover	0 895 90	DIY	0 893 37
	0 905 68		50	Φ 65	Masonry box, with DCL cover	0 895 90	DIY	0 892 37
	0 919 70		50	Φ 65	Masonry box, with cover		DIY	0 892 56

"All the commercial references listed above may be supplemented with a prefix of type LG-, BT-, ... (to indicate the brand) and/or suffix of type 0, 1, 2, 3, 4, FI, EX, ...

In this case, the products are technically the same."



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/10/2025

Signature:

  
LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
R.C.S. Nanterre 528 200 000  
33 avenue du Général Leclerc  
92260 FONTENAY-AUX-ROSES  
Certification Officer

## ANNEX (End)

Rated insulation voltage		450V
Nature of their material		Insulating
Method of installation	Flush type	Non-combustible walls, ceilings or floors Combustible walls, ceilings or floors
	Placement	Hollow walls, hollow ceilings, hollow floors or furniture
Type of inlets (outlets)		With inlets for plain or corrugated conduits
Clamping means		Without clamping means
Minimum and maximum temperatures during installation		From -5°C to +60°C
Degree of protection of the part mounted in the hollow wall		IP20
Arrangements to fix the accessories to the boxes		Boxes destined to receive another fixing means
Suspension means		For suspension of a luminaire

Accessories


References	Function	Making up	PRO/DIY
0 895 90	DCL cover for ceiling rose		PRO
0 905 69	DCL cover for ceiling rose	0 895 90	DIY



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 20/10/2025

Signature:



LABORATOIRE CENTRAL DES  
 INDUSTRIES ELECTRIQUES  
 S.A.S au capital de 15.745.984 €  
 33 avenue du Général Leclerc  
 92260 FONTENAY-AUX-ROSES

**Julien GAUTHIER**  
 Certification Officer