

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fixed socket-outlet (flush-type)
Name and address of the applicant	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong P. R. China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	6 170 45, 6 172 45, 6 173 45, 6 174 45, 6 176 45, 6 177 45 6 178 45
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	180900279SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 12 November 2019



Signature:

Hyden Li



Ratings and principal characteristics

13A 250V~, flush type, IP20, Class I, rewirable, with screw-type terminals, with 2 gang socket outlets comply with type G (configuration of BS 1363-2), with shutters, with plastic cover plate.

Additional information

Model Details see below

Mounting plate (style 1) with removable cover plate for model 6 170 45, 6 172 45, 6 173 45 and 6 174 45

Mounting plate (style 2) with removable cover plate for model 6 176 45, 6 177 45 and 6 178 45

6 170 45, 6 176 45: "White" front cover and cover plate

6 173 45: "Dark grey" front cover and cover plate

6 174 45: "Brown" front cover and cover plate

6 177 45: "Anthracite" front cover and cover plate

6 172 45, 617845: "Ivory" front cover and cover plate

Date: 12 November 2019

Signature:

