

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Adaptor

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

**NINGBO BANMEN ELECTRICAL APPLIANCE CO., LTD**  
NO 32 SANHAI RD EAST SECTION OF GUANHAIWEI  
INDUSTRIAL ZONE  
GUANHAIWEI TOWN CIXI CITY  
315314 NINGBO CITY ZHEJIANG - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

230V~ - Max 3680W - Class I - IPX0  
(Adaptor with USB charger and SPD)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

6 946 71

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR 657655 dated 28/05/2014. Update further to the evolution of the standard(s)

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013  
IEC 60884-2-5:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

154072-717357

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 22/01/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX

## CHARACTERISTICS

Standard Sheet	III (CEE7) for socket VII (CEE 7) for plug
Rated current (A)	16 A
Rated load (W)	Max. 3680 W
Rated voltage (V)	250 V~
Household voltage (V)	230 V~
Degree of protection	IPX0
Provision for earthing	with earthing contact
Type of connection	Soldered, riveted
Colour	Grey, white
<b>Socket-outlets</b>	
Degree of protection against electric shock	normal protection
Existence of shutters	with shutters
Method of application - mounting	portable type
<b>Plug</b>	
Class of equipment	I


Component	Model	Manufacturer	Conformity
USB	X17-USB-2	Ningbo Banmen	LCIE*
SPD	X5	Ningbo Banmen	LCIE **

\*) test report No. LCI-18MY2401VTSC

\*\*) test report No. BAN-13DE0806ITSC



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 22/01/2019

Signature: **Jean-François BRUEL**  
Certification Officer