

CERTIFICATE FI/42478 Issue 2

Our Ref. HEL-CERT210100070-28



Product Range of enclosures
Type CUBO O -series (OABP)
Trademark ENSTO
Certificate Holder Legrand Finland Oy
 Ensio Miettisen katu 2, FI-06150, Porvoo, Finland

Technical information
 Degree of protection (EN 60529): IP66 / IP67
 Mechanical strength (EN 62262): IK08 +35 °C / IK07 -25 °C
 Static loads: Mounting plate 2 kg/dm²
 Material: Acrylonitrile butadiene styrene (ABS)
 Nominal voltage: 1000 V AC and 1500 V DC

Other information
 Empty enclosure
 See page 2 of this Certificate.

The product is certified according to the following standard(s)
 EN IEC 62208:2023

Validity
 This certificate is valid until 27 April 2031 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 27 April 2026

SGS Fimko Oy

Signature



Jari Karlsson
 Certification Manager



Manufacturer Legrand Finland Oy
Ensio Miettisen katu 2, FI-06150, Porvoo, Finland

Manufacturing site Legrand Estonia OÜ
Keki 1, EE-76606, Keila, Estonia

Additional information Range of enclosures.
Wall mount enclosure.

The series includes the followings types:

Type	Size (mm)	Type	Size (mm)
OABP 202013 G/T	200 x 200 x 132	OABP 202018 G/T	200 x 200 x 187
OABP 203013 G/T	200 x 300 x 132	OABP 203018 G/T	200 x 300 x 187
OABP 204013 G/T	200 x 400 x 132	OABP 204018 G/T	200 x 400 x 187
OABP 303013 G/T	300 x 300 x 132	OABP 303018 G/T	300 x 300 x 187
OABP 304013 G/T	300 x 400 x 132	OABP 304018 G/T	300 x 400 x 187
OABP 306013 G/T	300 x 600 x 132	OABP 306018 G/T	300 x 600 x 187
OABP 404013 G/T	400 x 400 x 132	OABP 404018 G/T	400 x 400 x 187
OABP 406013 G/T	400 x 600 x 132	OABP 406018 G/T	400 x 600 x 187

The models OABP....018 G/T are assembled by adding an extension frame (55 mm) to the OABP....013 G/T models.

...G grey cover
...T transparent cover

For determining the electric strength, a test with voltage 5250 V according to IEC 60439-1 has been performed on the product. The product fulfills these requirements.

This certificate replaces previous certificate FI/42478 Issue 1, dated 2026-01-28, due to new testing.

As shown in the Test Report(s) No(s): HELES2510000837-1