

CERTIFICATE FI/40618/A1

Our Ref. HEL-CERT200300129-06



Product Terminal connecting unit
Type AL2
Trademark E E
Certificate Holder Ensto Building Systems Finland Oy
Ensio Miettisen katu 2, FI-06150, Porvoo, Finland
Technical information 6 mm², 450 V
Other information Connecting capacity:
Any combination 'r' and 'f' for 2 x 6 mm², 2...3 x 4 mm², 2...4 x 2,5 mm² and
's', 'r', 'f' for 6 + 2,5 mm², 6 + 2,5 + 2,5 mm²

The product is certified according to the following standard(s)
EN 60998-1:2004
EN 60998-2-1:2004

Validity This certificate is valid until 2025-03-23 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2021-04-29

SGS Fimko Ltd

Signature


Joonas Leinonen
Certification Manager



Manufacturer Ensto Building Systems Finland Oy
 Ensio Miittisen katu 2, FI-06150, Porvoo, Finland

Manufacturing site Ensto Building Systems Oü
 Keki 1, EE-76606, Keila, Estonia

Directive information The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Additional information This certificate replaces Certificate FI/40618, dated 2020-03-23, due to name change of certificate holder, manufacturer and factory.

As shown in the Test Report(s) No(s): 279882-1, 288279-3 and 298626-2