



Surface-mounted equipment Reversible Transformeur

Cat. No(s): **0 860 17L/20L**
0 861 14L/15L/17L/20L



1. USE

Lighting control mechanisms including or not identification elements (lights) or signaling elements (markings).

Lighting control mechanisms with possible functions:

- _ Simple two-way or simple push button.
- _ Double two-way or double push button.
- _ One two-way or one push button in right or left position.


Supplied in change-over push-button mode with 2 half-fingers or 1 wide finger mounted.

2. RANGE


		References
Configurable		0 860 17L
		0 860 20L
Surface-mounting complete		0 861 14L
		0 861 15L
		0 861 17L
		0 861 20L

3. OVERALL DIMENSIONS (mm)

■ Configurable



■ Surface-mounting



3. OVERALL DIMENSIONS (mm) (continued)

	A	B	C
Configurable	53.5	54.8	29.5
Surface-mounting complete	72	72	31.4

4. CONNECTION

Type of terminals: automatic

Terminal capacity: 1.5 mm² - 2.5 mm² (1 or 2 conductors)

Stripping length: 12 mm

5. TECHNICAL CHARACTERISTICS

■ 5.1 Protection index

Protection against solid bodies and liquids: IP 31D

Protection against impact: IK 04

■ 5.2 Material characteristics

Frame, support, rocker: ABS

Mechanism: PC

UV-resistant

Halogen-free

Self-extinguishing:

850°C/30 s for insulating components holding live parts in place.

650°C/30 s for other insulating components.

■ 5.3 Electrical characteristics

Voltage: 250 V~

Frequency: 50 Hz

Current: Push button version 10 A

Two-way version 10 AX


Maximum power on lamps with integrated ballast

(LED lamps and compact fluorescent): 100 W

■ 5.4 Climate characteristics

Usage temperature: - 10° to + 40° C

Storage temperature: - 25° C to + 60° C



6. CLEANING

Surface cleaning with a cloth.

Do not use: acetone, tar remover, trichloroethylene.

Maintenance with the following products: Hexane (EN 60669-1), Methylated spirit, Soapy water, Diluted ammonia, Bleach diluted to 10%, Window-cleaning products, Pre-saturated wipes.

Caution: A preliminary test should be carried out if other specific cleaning products are to be used.

7. STANDARDS AND APPROVALS

Compliance with standards of installation and manufacturing.
Refer to e. catalogue.